



*Providing Tomorrow's Solutions Today.*

**VIA CERTIFIED MAIL (70031010000120905469)**

July 10, 2013

Ms. Diana Esher  
Director, Air Protection Division  
US EPA, Region III  
1650 Arch Street  
Philadelphia, PA 19103

RECEIVED  
JUL 12 2013  
3AP20

**Re: 40 CFR Part 63 Subpart ZZZZ – Initial Notification of Applicability**

Dear Ms. Esher:

In accordance with the requirements of the referenced Stationary Reciprocating Internal Combustion Engine MACT Rule, PSC Industrial Outsourcing, LP (PSC) hereby submits the required initial notification on behalf of our client, van Hoekelen Greenhouses, Inc. (van Hoekelen).

If you have any questions, please call me at 215-997-7550 or Ms. Patricia Grier of van Hoekelen at 570-929-1917.

Thank you in advance for your assistance in this matter.

Sincerely,

  
JAY YOUNG  
Project Manager

\Encl.

cc (w/encl): Ms. Patricia Grier, van Hoekelen  
Mr. Michael Kurtz, van Hoekelen

Codefiles\van Hoekelen Greenhouses\40 CFR 63 ZZZZ Initial Notification

**Industrial Services Division**

2337 N. Penn Road, Hatfield, Pennsylvania 19440  
Tel (215) 997-7550 Fax (215) 997-7669 [www.PSCNow.com](http://www.PSCNow.com)

## Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:  
Stationary Reciprocating Internal Combustion Engines  
40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for  
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 42239

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

**Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:**

- Existing non-emergency compression ignition (CI) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: van Hoekelen Greenhouses, Inc.

Facility name (if different): \_\_\_\_\_

Facility (physical location) address: Rt 309, PO Box 88

McAdoo, PA 18237-0088

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: Cornelis van Hoekelen

Owner/company address: Rt 309 PO Box 88

McAdoo, PA 18237-0088

Owner telephone number: (570) 929 1917

Owner email address (if available) \_\_\_\_\_

**If the Operator information is different from the Owner, please provide the following:**

Operator name/title: (Same)

Operator telephone number: \_\_\_\_\_

Operator email address (if available): \_\_\_\_\_

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: 3 Engines as follows:

- (1) Kohler Model 500 ROZD71 500 KW Generator powered by a 830 HP 4 Stroke CI engine
- (2) Kohler Model 500 ROZD4 500 KW Generator powered by a 765 HP 2 Stroke CI engine
- (3) Onan Cummins 450 DFEC 450 KW Standby Generator powered by a 695 HP 4 Stroke CI engine

I hereby certify that the information presented herein is correct to the best of my knowledge.

Pat Grier  
(Signature)

7-9-13  
(Date)

Pat Grier Controller  
(Name/title)

(570) 929-1917  
(Telephone No.)